

**Field Inspection Tabulation Sheet**

**Visual Analysis of Fuel (Underground Tanks) at Retail Location**

**Date/Period: October 2013**

Site Reference	Date of Inspection	Product	Color	Clear/Bright	Hazy/Cloudy	Sediments	Water (Trace)	Other	Comments
<b>ESSO</b>									
Site E1	9-Oct-13	Diesel	Flourescent/Yellow	Yes	No	No	No		Petrofirst System in use
		Super	Light Yellow	Yes	No	Minute	No		VR indicates water in tank
		Regular	Light Yellow	Yes	No	Minute	No		VR indicates water in tank
Site E2	9-Oct-13	Super	Light Yellow	No	Yes	Yes	No		Foreign material in tank, follow up re'd; Retailer indicated previous comingling during delivery.
		Regular	Light Yellow	Yes	No	Minute	No		Follow up visual to be carried out in future
		Diesel	Flourescent/Yellow	No	Yes (mildly)	Yes	No		Follow up visual to be carried out in future
Site E3	10-Oct-13	Super	Light Yellow	Yes	No	Minute	No		
		Regular	Light Yellow	Yes	No	No	No		
		Diesel	Flourescent/Yellow	Yes	No	Minute	No		
Site E4	10-Oct-13	Super	Light Yellow*	Yes	No	No	No		* color mildly tainted pink, VR indicates water in tank
		Regular	Pale Gold (to pink)	Yes	Mildly	No	No		VR indicates water in tank
		Diesel	Flourescent/Yellow	Yes	No	Minute	No		
Site E5	10-Oct-13	Diesel	Flourescent/Yellow	Yes	No	No	No		
		Regular	Light Yellow	Yes	No	No	No		
		Super	Light Yellow	Yes	No	No	No		
Site E6	10-Oct-13	Diesel	Flourescent/Yellow	Yes	No	No	No		
		Regular	Pale Gold (to pink)	Yes	No	Minute	No		Mild color mismatch (w/ref. sample); VR indicates water in tank
		Super	Light Yellow	Yes	Mildly	Minute	No		Mild Fluid activity - warm period of day
Site E7	10-Oct-13	Diesel	Flourescent/Yellow	Yes	No	No	No		
		Super	Light Yellow	Yes	No	No	No		VR indicates water in tank
		Regular	Light pink/salmon	Yes	No	No	No		Mismatch between Site and reference sample
Site E8	10-Oct-13	Super	Light Yellow	Yes	No	No	No		Tanks buried deep, no water in sump
		Regular	Light Yellow	Yes	No	No	No		
		Diesel	Flourescent/Yellow	Yes	No	No	No		Water in diesel sump
Site E9	11-Oct-13	Super	Yellow (to gold)	Yes	Mildly	Yes	No		Tank component departing from vertical - indicates rotation of tank, to further discuss
		Regular	Light Yellow	Yes	No	No	No		(Retailer indicates water table and ground water flow issues)
		Diesel	Flourescent/Yellow	Yes	No	Minute	No		
Site E10 (Closed during exercise)	11-Oct-13								

VR = Veeder Root (Tank Monitoring/Inventory Management System)